



Consumer Confidence Report TCEQ Certificate of Delivery Texas Commission on Environmental Quality

For Calendar year: 2023 PWS Name: Ben Wheeler Water Supply Corp

PWS ID Number: TX2340006 Date Distributed to Customers: 06/26/2024

You must use at least one direct delivery and at least one good faith delivery method. If your system is under 500 population, please use Small System Certificate of Delivery form.

Direct Delivery Methods

- Mail a paper copy of the CCR
Mail notification that CCR is available on-line at https://benwheelerwater.com
\*The Internet link (url) you insert above must take customers directly to the open CCR.
Email direct web address of the CCR, available at https://benwheelerwater.com
Email CCR as an attachment to or an embedded image in an email.
Other direct delivery (for example, door hangers or additional electronic delivery method). Please specify:

Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL here: https://

Good faith delivery methods (To reach people who do not receive bills)

- Posting the CCR on the Internet at https://benwheelerwater.com
Mailing the CCR to people who receive mail, but who do not receive bills.
Advertising the availability of the CCR in news media.
Posting the CCR in public places.
Delivering multiple copies to single billing addresses serving multiple persons.
Delivering multiple copies of the CCR to community organizations.

I certify that the community water system named above has distributed the Consumer Confidence Report (CCR) for the calendar year of 2023 and that the information in the report is correct and consistent with the compliance monitoring data previously submitted to the TCEQ. Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the direct URL.

I have included a Public Notice requiring additional mandatory language NOT populated by the CCR generator and request for the Public Notice be reviewed for compliance.

Certified By:

Name (print): Allen Wheeler Title: General Manager Phone Number: 903+-833-5206
Signature: [Handwritten Signature] Date: 06/26/2024

All systems are required to mail by July 1 the Certificate of Delivery and Consumer Confidence Report to:

Sending by Regular Mail
TCEQ
DWSF, MC-155, Attn: CCR
PO Box 13087
Austin, TX 78711-3087

Sending by Certified Mail
TCEQ
DWSF, MC-155, Attn: CCR
12100 Park 35 Circle
Austin, TX 78753

# 2023 Consumer Confidence Report for Public Water System BEN WHEELER WSC

This is your water quality report for January 1 to December 31, 2023

BEN WHEELER WSC provides ground water from [insert source name of aquifer, reservoir, and/or river] located in [insert name of County or City].

Carrizo Wilcox

Van Zandt County

For more information regarding this report contact:

Name Allen Wheeler

Phone 903-515-0149

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono [903333-5206](tel:903333-5206).

## Definitions and Abbreviations

Definitions and Abbreviations

Action Level:

The following tables contain scientific terms and measures, some of which may require explanation.

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picocuries per liter (a measure of radioactivity)

## Definitions and Abbreviations

ppb: micrograms per liter or parts per billion

ppm: milligrams per liter or parts per million

ppq parts per quadrillion, or picograms per liter (pg/L)

ppt parts per trillion, or nanograms per liter (ng/L)

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Information about Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact [insert water system contact \[insert phone number\] 903-833-5206](tel:903-833-5206)  
**Allen Wheeler**

### Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1	Fecal Coliform or E. Coli MCL: A routine sample and a repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive.	1	N	Naturally present in the environment.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/05/2022	1.3	1.3	0.171	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

## 2023 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2023	20	19.8 - 19.8	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

\*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2023	44	44.3 - 44.3	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

\*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2023	0.043	0.028 - 0.043	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2023	0.1	0.111 - 0.24	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2023	0.0391	0 - 0.0391	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	07/21/2021	1.5	1.5 - 1.5	0	5	pCi/L	N	Erosion of natural deposits.

### Disinfectant Residual

A blank disinfectant residual table has been added to the CCR template, you will need to add data to the fields. Your data can be taken off the Disinfectant Level Quarterly Operating Reports (DLQR).

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Free Chlorine	2023	1.08	.68-1.58	4	4	PPM	ppm	Water additive used to control microbes.



Received by PWSCCR

PWSCCR <PWSCCR@tceq.texas.gov>

Thu 6/27/2024 5:54 AM

To: allen wheeler <allenbwheeler1@hotmail.com>

Your email to [PWSCCR@tceq.texas.gov](mailto:PWSCCR@tceq.texas.gov) for the CCR Team has been received!

Deadlines:

**May 1<sup>st</sup>** – Provider Certificates of Delivery are due to TCEQ for Wholesalers

**July 1<sup>st</sup>** – CCR's are due to TCEQ and customers for community water systems

Helpful Resources:

- [CCR Webpage](#)
- [Instructional YouTube Video](#)
- [Texas Drinking Water Watch \(DWW\)](#)
- [NEW Unregulated Contaminant Monitoring Rule Number 5 \(UCMR5\)](#)

**ATTENTION:** This email box should be used for general correspondence only. If your public water system is experiencing an emergency condition(s) that may pose a sudden threat to public health or you need immediate assistance, please notify the TCEQ region that serves your county. Contact information for TCEQ regional offices can be located at [TCEQ Regional Directory](#). **Please use the TCEQ's emergency hotline, after business hours, at 1-888-777-3186.**

-